



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

**Certificate No.: CE200306006828**

***Product***

Automatic Transfer Switching Equipment

***Applicant***

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

***Type/Model***

TGQ1N-63M/3,TGQ1N-63M/4,TGQ1N-63H/3,TGQ1N-63  
H/4;

***Technical data***

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.  
03601-A-19D0076-S, the submitted sample(s) of the above item complies with:

**EN 60947-6-1:2005 + A1:2014**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

**Valid from:** Jun.11,2020

**Valid until:** Jun.11,2023

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



# CHINA QUALITY CERTIFICATION CENTRE

## CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE200306006828

TGQ1N-63M/3,TGQ1N-63M/4,TGQ1N-63H/3,TGQ1N-63H/4;

Ui:500V(main circuit);400V(control and auxiliary circuits);

Uimp:4kV(main circuit);2.5kV(control and auxiliary circuits);

Ue:AC400V;

Ie: 10A,16A,20A,25A,32A,40A,50A,63A;

Utilization Category:AC-33iB;

Icn: Type M:6kA, Type H: 10kA;

Icm(peak value): Type M:9.2kA, Type H:17kA;

Class of equipment: CB;

Method of controlling:

RTSE(only intelligent type with communication controller),

ATSE;

3P, 4P;

IP20.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>